

EC Type-Examination Certificate



according to Directive 2009/142/EC Article 8, section 1. (a)
relating to appliances burning gaseous fuels

Certificate No.: MB 69251041 0001 PIN: 1008 CQ 2928

Test Report No.: 28229753 001

Certificate Holder: Pakole Trade Kft.
H-8000 Székesfehérvár, Börgöndi út 8 - 10.

Manufacturer: Pakole Trade Kft.
H-8000 Székesfehérvár, Börgöndi út 8 - 10.

Product: Group: Heating and air conditioning appliances
Indirect gas-fired forced convection air heaters for
space heating (3321)

Identification: Model: GTV-..., AGS-...
See details in Annex I.

Tested according to: EN 1020:2009

Countries of destination: DK, EE, FI, LT, LV, NO, SE, LU, DE, BE, FR, CY, NL, BA,
BG, MD, RO, RU, SK, UA, HR, CH, ES, GB, IE, PT, SI, CZ,
GR, IT, AT, TR, PL, HU

This type-examination certificate refers to the above mentioned product. This is to certify that the test sample is in conformity with the essential requirements of Annex I of the Directive. The Certificate Holder is entitled to use this certificate in connection with the EC Declaration of Conformity in accordance with the Directive. This certificate does not imply assessment of the series production of the product and does not permit the use of a TÜV Rheinland mark of conformity. This certificate itself does not permit the affixing of CE marking followed by the identification number of the notified body.

Date of issue:
Budapest, 15.10.2015



TÜV Rheinland InterCert Kft. – Product Certification Body — H-1132 Budapest, Váci út 48/A-B — www.tuv.hu
Notified under No. 1008 to the EC Commission

CE The CE marking may be used if all relevant and effective EC directives are complied with. CE

Annex I to certificate No. MB 69251041 0001

Page 1/1

PIN: 1008 CQ 2928

Model	Appliance category	Supply pressure (mbar)	Countries of destination
GTV-20 AGS-20 ... GTV-116A AGS-116A	I _{2H}	20	DK, EE, FI, LT, LV, NO, SE
	I _{2E}	20	LU, DE
	I _{3P}	37	BE, FR
		50	CY, DE,
	II _{2H3P}	20, 28-30	BA, BG, MD, RO, RU, SK, UA, HR, RS
		20, 37	CH, ES, GB, IE, PT, SI
		20, 28-30, 37	CZ, GR, IT
II _{2E3P}	20, 50	AT, TR	
II _{2E3P}	20, 37	PL	
GTV-20 AGS-20 ...	II _{2HS3P}	25, 28-30, 50	HU
GTV-58A AGS-58A	II _{2L3P}	25, 28-30, 50	NL
GTV-68 AGS-68 ...	II _{2H3P}	25, 28-30, 50	HU
GTV-116A AGS-116A	I _{3P}	50	NL

Model	Nominal heat input (kW)
GTV-20, AGS-20	20
GTV-27, AGS-27	27
GTV-33, AGS-33	33
GTV-40, AGS-40	40
GTV-48, AGS-48	48
GTV-58, AGS-58	58

Model	Nominal heat input (kW)
GTV-68A, AGS-68A	68
GTV-78A, AGS-78A	78
GTV-87A, AGS-87A	87
GTV-97A, AGS-97A	97
GTV-107A, AGS-107A	107
GTV-116A, AGS-116A	116

 Flue system: B₂₂, C₁₂, C₃₂, C₅₂

Electrical supply: 230V, 50 Hz

The appliances were tested together with the flue evacuating system, required by the manufacturer.

The models of the applied flue pipes: LIM-MONT ECO DIM DW; LIM-MONT ECO DIM DE.

Certification Body

Date of issue:

Budapest, 15.10.2015

TÜV Rheinland InterCert Kft. – Product Certification Body — H-1132 Budapest, Váci út 48/A-B — www.tuv.hu